



RFP 121214

Addendum #1

Posted Date: 12-23-14

Clarifications and additional work.

The purpose for this addendum is to clarify certain parts of the scope of work and to include flooring with this RFP

The top lines were left off the Exhibit "G". These two lines state the following.

New breaker in MSA and it will be an 80 AMP.

The new electrical panel shall supply all the power for rooms 123, 125, 128, 131, 133, 135, 150, 153.

Electrical outlets are to be installed in ceilings for overhead projectors in rooms 123, 125, 131, 133, 150, 153.

Existing Lights to be R&R in new ceiling grid.

Next: All existing flooring to be removed from rooms 123, 125, 128, 131, 133, 135, 150, 153. These rooms to have SHAW, Channel Stitch and color will be Raffia 2'x2' carpet tile to be added to this project and included in proposal as well as the removal of existing flooring.

Ceiling and lights to be left in place in room 125.

Please sign and date below and attach addendum to the bid package submitted.

I, by signing below acknowledge receipt of the posted addenda, and understand that it becomes part of the bid package for submission.

Signature: _____

Date: _____