



**RFP-16-EW-397155**

**Addendum #3**

**Posted Date: 02-18-16**

**Clarification**

- 1. Eave height for new extension shall be match up with existing hangar. It is listed as 16'8" in Addendum 02 incorrectly. The eave ht. is 18'6" at the existing hangar.**

Please sign and date below and attach addendum to the bid package submitted.

I, by signing below acknowledge receipt of the posted addenda, and understand that it becomes part of the bid package for submission.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_