



RFP-16-EW-397155

Addendum #4

Posted Date: 02-24-2016

Clarification and Revisions on Alternate 01

Contractor to relocate the existing 3 way switching and extend the existing lighting circuits, move the existing exit and adding an emergency light and add (2) NEW circuits from the existing panel for the (6) new quad-plex receptacles.

Scope of work states there are to be 32 interior light fixtures. There will only be 12 interior light fixtures.

Please sign and date below and attach addendum to the bid package submitted.

I, by signing below acknowledge receipt of the posted addenda, and understand that it becomes part of the bid package for submission.

Signature: _____

Date: _____