



RFP-19-ND-004
TSTC Waco Airport Flight-line Structures
SUBMITTAL DUE DATE: Thursday, May 9, 2019 at 2:00 pm

ADDENDUM # 1
(Posted 5.2.19)

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes. The following information becomes a permanent part of the RFP...

This addendum includes...

1. Questions and Answers.

Questions and Answers

Question #1: Do you happen to have drawings for the project?

A: **We do not have any drawings. Part of the scope is for the builders to provide drawings and engineering. This is kind of a "design/build" project in that way. Refer to section 2.3.2 of RFP.**

2.3.2 Project Specifications:

1. Provide (2) 60'L x 60'W x 20'H (clear at the underside of the ridge), clear-span, roof-only shelters—both having a 12:1 roof slope, 17'-6" open wall height on the sides ($\pm 3"$), and ends that are completely open
2. Provide a design, elevation drawings, and P.E. stamped engineering for the structures
3. Provide a turnkey installation on existing 13" thick concrete
4. Shelters shall be wind-rated to 90mph
5. Shelters shall be independent of each other

Question #2: Is this what you are looking for, for the two 60ft x 60ft (20ft tall side wall) buildings?

A: **We are happy to receive proposals for Tension Fabric structures provided they meet the criteria listed in section 2.3.2 "Project Specifications" of the RFP.**

Question #3: I'd like to know how much is the estimated budget for the project? And lastly, is this project still bidding on May 9 at 2:00 PM (CDT)?

A: **Bid responses are due on May 9th and unfortunately we cannot disclose price.**

End Questions and Answers

Nereida Dominguez, CTPM

Buyer I

Phone: (956) 364-4429

Email: nereida.dominguez@tstc.edu

In submission of this bid, bidder must acknowledge receipt of this addendum, otherwise bid will not be given consideration. Bidder must acknowledge receipt by including a copy of this notice with bid.

Bidder Signature _____

Printed Name _____

Vendor Name _____

Vendor Identification Number _____

Date: _____

End of Addendum
