

80 Amp
To MSA

NEW - 100 Amp DISCONNECT for PRIMARY of TA.

NEW - 42 CIRK Panel with 150 Amp MAIN

NEW - 45 KVA Transformer 480/208




EXHIBIT G

- * OWNER FURNISHED PANDUIT WALL DUCT - CONTRACTOR MOUNTED AND WIRED
- * OWNER FURNISHED/CONTRACTOR INSTALLED LATCH/UNLATCH CONTACTORS
- * CAP OFF ALL EXISTING CIRCUITS IN J BOXES
- * INSTALL BACK BOXES FOR F/A WHERE REQUIRED
- * INSTALL BOXES FOR DATA & PHONE - 3/4 MIN STUB
- * CONNECT EXISTING POWER BACK TO VAV BOXES IF NEEDED

